

Q&A 16/17-03 Underground Chilled Water Connection

Question Deadline: 8/29/16

Answer Deadline: 9/1/16

Page 1 of 1

#	Question	Answer
1	Who is responsible for removal of the vegetation next to the building (trees, shrubs)?	Palm Beach State College
2	Who is responsible for providing concrete barriers for traffic control?	The contractor
3	Will a staging area be provided to store piping?	Yes
4	Will the college hire the controls contractor directly?	The college will hire the controls contractor directly and the controls contractor will provide the valves with actuators. Please see the attached ' Project Scope of work and Proposal ' from Advanced Control Corporation. The attachment has comments embedded from the engineer. The response from Advanced Control Corporation to these comments are as follows: "The valve actuators are being provided with end switches and we do have the point capacity required to receive this information. In regards to the flow meter, we will install and mount the flow meter but will need the mechanical contractor to install a 1" threadlet with a hot tap valve that we will provide to them. This will allow them to fill the pipes and we can install the flow meter at a later time."